

COPPER

Contaminant	In Water As	Maximum Contaminant Level
Copper (Cu)	Cu ²⁺	USEPA Action Level* = 1.3 mg/L MCLG** = 1.3 mg/L WHO [†] Guideline = 2.0 mg/L
Sources of Contaminant	Industrial discharges Copper salts used for algae control in reservoirs Copper plumbing materials due to corrosion	
Potential Health Effects	Acute copper poisoning: nausea, vomiting, diarrhea, gastrointestinal illness, abdominal and muscle pain. Severe cases of copper poisoning have led to anemia, liver poisoning, and kidney failure.	
Treatment Methods Point-of-Entry (POE) Point-of-Use (POU)	Reverse Osmosis Distillation Cation Exchange	

*Action Level requires water utilities to sample specific number of samples in specific locations and verify that 90% of samples are below this level. If that is not met, an appropriate Action is required to be taken to remedy the situation.

**Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety and are non-enforceable public health goals.

WHO[†] - World Health Organization

Copper is a metallic element that is essential to human health. Too little is unhealthy and too much can lead to copper poisoning. The body cannot synthesize copper so the human diet must supply regular amounts for absorption. The daily requirement is about 2 mg of copper intake per day to maintain a balance of 75-100mg in the adult body². In the UK, it is now recommended that the daily intake should range from 0.4 mg/day for 1-3 year old children to 1.2 mg/day for adults⁴. Maximum intake of copper should not exceed 12 mg/day for adult males and 10 mg/day for adult females⁴. Recent surveys show only 25% of the US population consume the amount of copper per day estimated to be adequate by the US Food and Nutritional Board of the National Academy of Sciences. Ironically, the US Centers for Disease Control (CDC) has reported cases of copper poisoning.

Benefits from Copper: Copper combines with certain proteins to produce enzymes that act as catalysts to help a number of body functions. Some help provide energy required by biochemical reactions. Others are involved in the transformation of melanin for pigmentation of the skin and still others help to form cross-links in collagen and elastin and thereby maintain and repair connective tissue. This is especially important for the heart and arteries.

Copper Deficiency: Children on diets deficient in copper have ineffective collagen synthesis, and may develop bone disease. Subclinical copper deficiency has been suggested as a risk factor for cardiovascular disease. People with Menkes disease, in which there is a failure of copper transport in the intestinal mucosa, show mental retardation, depigmentation, severe anemia and bone problems.

Copper Poisoning: Acute copper poisoning can cause symptoms of nausea, vomiting, diarrhea, gastrointestinal illness, abdominal and muscle pain. Severe cases of copper poisoning have led to anemia, liver poisoning, and kidney failure^{3, 4}.

Copper in water exists as a divalent ion, Cu^{+2} . Levels over 0.05 mg/L are not naturally encountered in groundwater¹. The presence of copper in water can be from industrial discharges or from copper salts used for algae control in reservoirs. Since copper is a common plumbing material, another source for copper is at the point of use due to corrosion.

HEALTH EFFECTS

The U.S. Department of Health & Human Services; Centers for Disease Control (CDC) reported two outbreaks of copper poisoning in Florida involving 37 people during 1997-1998. The first case involved two people becoming ill after consuming fruit drink made with tap water. Improper wiring and plumbing procedures caused leaching of copper from restaurant piping. Copper levels reached 3.6 mg/L in the tap water after leaching. The second case involved 35 persons in one community with gastrointestinal illness. A defective check valve and a power outage led to a malfunction at a water treatment facility. High levels of sulfuric acid corroded the pipes and leached copper into the system. Copper levels of 33 mg/L and 138 mg/L with $\text{pH} < 6$ were found in two water samples collected on the day of the malfunction¹. The CDC reported two cases in Wisconsin where elevated copper levels in tap water were associated with gastrointestinal illness. The first case in September 1995 involved 22 people; the second case in October 1995 involved 15 people. The homes in the community had recently been built or remodeled and new copper plumbing was thought to have contributed to the contamination of the water.¹

The Wisconsin Department of Health and Social Services reported a case of methemoglobinemia in an infant during 1992 that was associated with ingestion of nitrate and copper-containing water. The symptoms described in the report appeared to have been induced by simultaneous exposure to copper and nitrates at levels close to federal drinking water standards. Copper is an effective emetic and gastrointestinal irritant, and concentrations in the 2.8-7.8 mg/L range have been associated with vomiting and diarrhea among adults and school age children. The dose required to cause acute symptoms in infants is unknown and children aged less than 1 year may be more sensitive to copper than older persons. Elevated copper levels in water used to prepare an infant's formula may cause loose stools and vomiting after eating.¹

Other adverse health effects from copper are associated with a genetic disorder known as Wilson's Disease. This genetic defect causes copper to accumulate in the liver, brain and other vital organs immediately after birth which eventually results in hepatitis, psychiatric, or neurologic symptoms. It is

fatal unless detected early. According to the Wilson Disease Association⁶ this disease affects approximately one in 30,000 people worldwide. When diagnosed early, Wilson’s disease is treatable and most people with the disease live normal lives.

TREATMENT METHODS

<p>Residential</p> <p>Point-of-Entry Point-of-Use</p>	<p>Reverse Osmosis Distillation Cation Exchange</p>
<p>Municipal</p>	<p>Polyphosphate feeds Buffering pH adjustment</p>
<p>Visit WQA.org or NSF.org to search for products certified to NSF/ANSI 58, 53, 62, WQAS-400, WQAS-200 for copper reduction claims.</p>	

Copper levels may be reduced at the point of entry by water softening. If copper is present due to corrosion, the copper corrosion may be controlled at the point of entry with a neutralizing system or with polyphosphate feed.

Since copper corrosion carries with it the possibility of lead dissolution, it is preferred to reduce copper from drinking water at the point of use with reverse osmosis (RO) or distillation.

The treatment methods listed below are generally recognized as techniques that can effectively reduce the listed contaminants sufficiently to meet or exceed the relevant MCL. However, this list does not reflect the fact that POU/POE devices and systems currently on the market may differ widely in their effectiveness in treating specific contaminants, and performance may vary from application to application. Therefore, selection of a particular device or system for health contaminant reduction should be made only after careful investigation of its performance capabilities based on results from competent equipment validation testing for the specific contaminant to be reduced.

As part of the installation procedure, system performance characteristics should be verified by tests conducted under established test procedures and water analysis. Thereafter, the resulting water should be monitored periodically to verify continued performance. The application of the water treatment equipment must be controlled diligently to ensure that acceptable feed water conditions and equipment capacity are not exceeded.

REGULATIONS

In the United States the EPA, under the authority of the Safe Drinking Water Act (SDWA), has set the Maximum Contaminant Level Goal (MCLG) for copper at 1.3 mg/L (or ppm). This is the health-based goal at which no known or anticipated adverse effects on human health occur and for which an adequate margin of safety exists. The USEPA has set an action level for copper in drinking water at 1.3

mg/L. This means that utilities must ensure that water from the customer's tap does not exceed this level in at least 90 percent of the homes sampled. The utility must take certain steps to correct the problem if the tap water exceeds the limit and they must notify citizens of all violations of the standard.

Copper is also regulated by the USEPA as an aesthetic contaminant (metallic taste) under the National Secondary Drinking Water Regulations⁵ (NSDWRs) at a Secondary Maximum Contaminant Level (SMCL) of 1.0 mg/L. Copper at this concentration is rare in public drinking waters and is not considered to be a health concern.

REFERENCES/SOURCES

- 1 – Center for Disease Control and Prevention - www.cdc.gov/mmwr/PDF/ss/ss4904.pdf
- 2 – Committee on Dietary Allowances of the National Research Council
- 3 – Committee on Copper in Drinking Water, National Research Council. The National Academies News. March 2, 2000.
- 4 – Copper Development Association - http://www.copper.org/consumers/health/cu_health_uk.html
- 5 – USEPA - <http://water.epa.gov/drink/contaminants/secondarystandards.cfm>
- 6 – Wilson's Disease Association - <http://www.wilsonsdisease.org/>
- 7 – World Health Organization. Copper in Drinking Water (2004).
http://www.who.int/water_sanitation_health/dwg/chemicals/copper.pdf

ACKNOWLEDGEMENT

WQA wishes to express sincere appreciation for the unselfish contributions of the members of WQA who contributed their time and expertise toward the completion of this bulletin.

Arvind Patil, Ph.D., CWS-I
Gary Hatch, Ph.D.
Charles Michaud, CWS-VI
Mark Brotman, CWS-VI
P. Regunathan, Ph.D.
Rebecca Tallon, P.E.

Richard Andrew
Shannon Murphy
Steve VerStrat
Pauli Undesser, M.S., CWS-VI
Kimberly Redden, CWS-VI

The Water Quality Association publishes this Technical Application Bulletin as a service to its members and the interested public. Information contained herein is based upon the most recent public data known as of the publication date, which is printed at the bottom of the last page, and of course, cannot take into account relevant data published thereafter. The Water Quality Association makes no recommendations for the selection of a treatment system, and expressly disclaims any responsibility for the results of the use of any treatment method or device to reduce or remove a particular contaminant.

This reference document is published by:



National Headquarters & Laboratory

**4151 Naperville Road • Lisle, Illinois 60532
Tel: 630 505 0160 • Fax: 630 505 9637**

Copyright © 2013 by Water Quality Association. All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electric, mechanical, photocopying, recording, or otherwise, without the prior written permission of the publisher.